



Product Service

CERTIFICATE

No. Z2 114675 0001 Rev. 00

Holder of Certificate: **ELIN Elektrik Ins. Ms. Proje Taah.
ve San. A.S.**
mit Mah. 2535. Sok. No. 1
Cankaya
06810 Ankara
TURKEY

Certification Mark:



Product: **Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TV SD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 713205734

Valid until: 2026-10-26

Date, 2021-10-29

(Gian Maria Fontolan)



CERTIFICATE

No. Z2 114675 0001 Rev. 00

Model(s): ELNSM60M-HC-HV-360, ELNSM60M-HC-HV-365
 ELNSM60M-HC-HV-370, ELNSM60M-HC-HV-375
 ELNSM72M-HC-HV-430, ELNSM72M-HC-HV-435
 ELNSM72M-HC-HV-440, ELNSM72M-HC-HV-445
 ELNSM72M-HC-HV-450, ELNSM72M-HC-HV-455

Parameters:

Construction:	Framed, with Junction Box, Cable and Connectors
Safety Class:	Class II
Maximum System Voltage:	1500Vdc
Fire Safety Class:	Class C according to UL790
Power:	from 360W to 455W, according model specifications
No. of Cells:	60 or 72, according model specifications
Protection degree:	IP 68

Tested according to:

IEC 61215-1:2016
 IEC 61215-2:2016
 IEC 61215-1-1:2016
 IEC 61730-1:2016
 IEC 61730-2:2016
 IEC 62716:2013
 IEC TS 62804-1:2015
 IEC 61701:2011
 EN 61215-1:2016
 EN 61215-2:2017
 EN 61215-1-1:2017
 EN 61730-1:2018
 EN 61730-2:2018
 EN 62716:2013
 EN 61701:2012