

## CERTIFICATE OF CONFORMITY

<b><u>Product :</u></b>	Electric cables for photovoltaic systems with a voltage rating of 1,5 kV DC
<b><u>Tested by request of:</u></b>	Yusuf Kabukçu Nak Kablo Elektrik Malz. İnşaat İnşaat İthalat İhracat San. Tic. LTD. ŞTİ. Bozburun Mah. 7045 Sok. No:9 Merkezefendi Denizli Türkiye
<b><u>Rating and principal characteristics:</u></b>	1,0/1,0 kV , Rated Temperature -40°C to +90°C Maximum conductor temperature 120°C
<b><u>Trade mark (if any)</u></b>	NAK SOLAR CABLE
<b><u>Model/Type ref:</u></b>	1x1,5 mm <sup>2</sup> - 1x240 mm <sup>2</sup>


**Additional information (if any)**

A sample of the product has been tested and found to be in conformity with the current IEC 62930:2017 & EN 50618 :2014

This statement is the result of testing a sample of the product submitted, in accordance with the the revelant specific standard



06.08.2021

  
S. Müge Okumuş  
E&E Division Manager

